



Office of the Vice President
and Chief Financial Officer
Procurement Services
<https://procurement.ufl.edu/>

971 Elmore Drive
PO Box 115250
Gainesville, FL 32611-5250
(352) 392-1331 Fax 352-392-8837

March 31, 2020

ADDENDUM NUMBER 2 ON INVITATION TO BID ITB20DB-137

TITLE: Window Replacement – Riker Hall

Mandatory pre-bid meeting was held at the site on March 16, 2020 at 10:00 AM for Lots 2 and 3. **Bid opening** will be held April 3, 2020 at 3:00 PM in UF Procurement Services, 971 Elmore Drive, Gainesville, FL 32611.

This addendum shall be considered part of the Contract Documents for the above-mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract documents, this addendum shall govern and take precedence. Bidders are hereby notified that they shall acknowledge receipt of the addendum.

This addendum consists of:

1. Additional Responses to vendor's questions.
2. Revised price sheet.

Regards,

Nicola Heredia
Director, Procurement Services

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM 3 AND RETURN WITH YOUR BID. FAILURE TO ACKNOWLEDGE THIS ADDENDUM COULD CONSTITUTE REJECTION OF YOUR BID.

VENDOR NAME

VENDOR ADDRESS

SIGNATURE

Answers to Questions Submitted

Q1: What kind of glazing should be used for this project?

A1. Clear, Argon filled double pane, Low-E 3 on the #2 surface with tint to be priced as additive alternate, as per Section 08 5313 Vinyl Windows 2.04 Components.

Q2. Specifications call for S-dry or MC19 for concealed locations, and Kiln-dry or MC15 for exposed locations. Can standard pressure treated lumber be used for both concealed and exposed locations?

A2. Kiln dried wood (MC15) should be used for all locations.

REVISED (3/31/2020) PRICE SHEET

From: _____
(Company Name/Name & Title of Authorized Agent)

To: **UNIVERSITY OF FLORIDA**
Procurement Services
971 Elmore Drive/PO Box 115250
Gainesville, FL 32611

The undersigned, being invested with the authority of his/her employer, and having read the Documents for the Bid, as well as the Specifications for the Bid, entitled:

ITB20DB-137: Window Replacement for Riker Hall

and having familiarized themselves with all conditions affecting and governing the specifications, pricing and delivery of the product and services described herein, hereby proposes to furnish the products and services as per the specifications, in strict compliance with the Bid Documents, Addenda and any other documents relating thereto on file with UF Procurement Services and, if awarded the Contract, agrees to abide by the pricing and delivery terms as per the Documents and as stated herein, for the sums enumerated on this page.

	As Specified (Pella)	Alternate Windows (Marvin)
Lot 1:		
Windows (including shipping):	\$:	\$:
Additive Alternate (Tint)	\$:	\$:
Lot 2:		
Installation:	\$:	\$:
Lot 3:		
Windows and Installation: (including shipping)	\$:	\$:
Additive Alternate (Tint)	\$:	\$:
Information Only:		
Lead Time:		

I have carefully prepared this Bid from contact documents described above, I have full authority to make such statements and submit this Bid in (my) (its) (their) behalf, and all statements are true and correct.

(Signature) (Printed or typed)

(Address, City State, Zip)

(Telephone) (Date)