

Office of the Vice President  
and Chief Financial Officer  
Procurement Services  
<https://procurement.ufl.edu/>

971 Elmore Drive  
PO Box 115250  
Gainesville, FL 32611-5250  
(352) 392-1331 Fax 352-392-8837

March 10, 2021

**ADDENDUM NUMBER 2 ON INVITATION TO BID ITB21DB-132**

**TITLE: Annual Contract for Pressure Washing Services for Garage Parking Surfaces**

This addendum shall be considered part of the Contract Documents for the above mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract documents, this addendum shall govern and take precedence. Bidders are hereby notified that they shall acknowledge receipt of the addendum.

**NOTES:**

This addendum consists of:

- Answers to Contractor questions and request for clarification.



Debbie Berrier  
Procurement Agent II

**PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM 2 AND RETURN WITH YOUR BID. FAILURE TO ACKNOWLEDGE THIS ADDENDUM COULD CONSTITUTE REJECTION OF YOUR BID.**

---

VENDOR NAME

---

VENDOR ADDRESS

---

SIGNATURE

## Questions and Answers

Q1. Are there discharge limits on the sanitary sewer system? What about solid waste? Is it necessary to pretreat wastewater?

*A1. There are no discharge limits. Solid waste will need to be separated, and can not go into the sanitary sewer system. Solid waste must be transferred off campus to a solid waste collection center.*

Q2. Are we quoting for 2 cleanings per year per garage?

*A2. Pricing should be provided per cleaning for each individual garage. (Garages 2, 3, and 10 are anticipated to be cleaned twice per year, all others are anticipated to be cleaned once per year.)*

Q3. Who is responsible for supplier employee COVID testing?

*A3. Vendors are responsible for ensuring their employees follow UF and CDC guidelines regarding COVID. UF Guidance for employees: <https://hr.ufl.edu/covid-19/additional-information-for-leaders/ufhr-guidance-to-hr-liaisons-on-covid-19-response-for-employees/>. CDC guidelines: <https://www.cdc.gov/coronavirus/2019-ncov/index.html>.*

Q4. Is there a need for steam control in garages with less open air due to fire alarm system?

*A4. Garage 12 has an underground section with fire suppression system. Steam will need to be controlled in this area in order to not set off the fire alarm system.*

Q5. Is water and power available at garages?

*A5. All garages on campus have water and power.*

Q6. Do elevators or Electric Vehicle chargers require special treatment?

*A6. Yes, elevators and EV charging stations should be protected from water and damage at all times.*