

Office of the Vice President
and Chief Financial Officer
Procurement Services
<https://procurement.ufl.edu/>

971 Elmore Drive
PO Box 115250
Gainesville, FL 32611-5250
(352) 392-1331 Fax 352-392-8837

May 12, 2022

ADDENDUM NUMBER 3 ON INVITATION TO BID ITB22KO-133


TITLE: Mound Septic System at IFAS GCREC in Wimauma, FL

Mandatory Pre-Bid Meeting was held at the site on April 26, 2022 at 11:00 AM. **Bid opening** is scheduled for May 19, 2022 at 3:00 PM in UF Procurement Services, 971 Elmore Drive, Gainesville, FL 32611.

This addendum shall be considered part of the Contract Documents for the above-mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract documents, this addendum shall govern and take precedence. Bidders are hereby notified that they shall acknowledge receipt of the addendum.

This addendum consists of:

- Responses to questions and requests for clarifications received prior to May 6, 2022 at 5:00PM.
- Reminder: Bids are due no later than May 19, 2022 at 3:00PM. Submit bids as stated in Item 4. BID SUBMITTAL, page 5, of the Bid Documents.



Karen Olitsky
Procurement Agent III

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM 3 AND RETURN WITH YOUR BID. FAILURE TO ACKNOWLEDGE THIS ADDENDUM COULD CONSTITUTE REJECTION OF YOUR BID.

VENDOR NAME

VENDOR ADDRESS

SIGNATURE

Questions and Answers

Q1. Ebara pumps are listed in the design specification. Will an equal substitute be allowed for the Ebara pumps?

A1. Yes, other manufacturers will be allowed as long as the pump's performance is comparable to the Ebara pumps, such as gpm, pump curves, voltage, amperage, hp, etc.

Q2. Will there be updated electrical plans for this project?

A2. No. Bidders are only responsible to connect the lift stations pumps/controllers to the owner supplied electrical source. Owner is in the process of upgrading the electrical to accommodate the new pumps.