



Office of the Vice President
and Chief Financial Officer
Procurement Services
<https://procurement.ufl.edu/>

971 Elmore Drive
PO Box 115250
Gainesville, FL 32611-5250
(352) 392-1331 Fax 352-392-8837

September 13, 2022

ADDENDUM NUMBER 3 ON INVITATION TO BID ITB23KO-106

TITLE: Reitz Lawn and Inner Road Utility and Roadway Improvements

Mandatory Pre-Bid Meeting was held August 16, 2022 at 12:00 PM. **Bid opening** is scheduled for September 22, 2022 at 3:00 PM in UF Procurement Services, 971 Elmore Drive, Gainesville, FL 32611.

This addendum shall be considered part of the Contract Documents for the above-mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract documents, this addendum shall govern and take precedence. Bidders are hereby notified that they shall acknowledge receipt of the addendum.

This addendum consists of:

1. Addendum 3.
2. Revised Specifications as referenced in attached Addendum 3. Updated Specifications are available for download here: <https://procurement.ufl.edu/vendors/schedule-of-bids/>
3. Revised Drawings as referenced in attached Addendum 3. Updated Drawings are available for download here: <https://procurement.ufl.edu/vendors/schedule-of-bids/>

Karen Olitsky
Procurement Agent III

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM 3 AND RETURN WITH YOUR BID. FAILURE TO ACKNOWLEDGE THIS ADDENDUM COULD CONSTITUTE REJECTION OF YOUR BID.

VENDOR NAME

VENDOR ADDRESS

SIGNATURE

ADDENDUM NUMBER 3 SEPTEMBER 12, 2022

The following additions, deletions, and/or changes or clarifications to the drawings and specifications shall become and are hereby made part of the Contract Documents. They change the original documents only in the manner and to the extent stated.

GENERAL:

This document summarizes changes made to the 100% Construction Documents dated June 10, 2022.

DRAWING REVISIONS:

- A. C-000
 - 1) Revised: Demolition and Restoration legends.
- B. C-003
 - 1) Added:
 - a. Picnic table north of TH-20.
 - b. Light pole north of TH-23.
- C. C-004
 - 1) Added: Picnic table north of SM-3D3-1/3.
- D. C-005
 - 1) Added:
 - a. 3" tree southeast of TH-43.
 - b. Additional information for sign at northeast corner of Inner Road and Newell Drive.
- E. C-006
 - 1) Removed: bench in front of Broward Dining.
 - 2) Added:
 - a. Dumpsters and trash cans on north side of Inner Road.
 - b. Rocks in landscaping area in front of Broward Dining.
- F. C-007
 - 1) Added:
 - a. Two (2) 4" trees north of Mallory parking lot.

- b. Trash cans along sidewalk on north side of Inner Road and south of Mallory parking lot.

G. C-103

- 1) Added:
 - a. Removal of existing light pole.
 - b. Removal of light pole in the drawing legend.

H. C-104

- 1) Added:
 - a. Removal of existing picnic table.
 - b. Removal of picnic table in the drawing legend.

I. C-105

- 1) Removed: Errant line at northwest corner of Inner Road and Newell Drive.
- 2) Added: Removal of a tree at southwest corner of Inner Road and Newell Drive.

J. C-105A

- 1) Revised: Note #3.

K. C-106

- 1) Removed: Removal of bench in front of Broward Dining.
- 2) Added:
 - a. Removal of dumpsters and trash cans on north side of Inner Road.
 - b. Dumpster removal in drawing legend.

L. C-107

- 1) Added:
 - a. Removal of trash cans along sidewalk on north side of Inner Road and south of Mallory parking lot.
 - b. Removal of existing steam trap protective barrier.
 - c. Alternate #2 callout to note 8.

M. C-207

- 1) Added:
 - a. Note 7 callout to 2" PC and 4" 70S at SM-3D3-84.
 - b. Note 7.
- 2) Removed: Note 7 callout at the end of run to SM-4D-1.

- N. C-210
1) Added: Light pole reinstallation.
- O. C-211
1) Added:
a. Detail D callout at stairs.
b. Replacement of existing picnic table.
c. Picnic table to drawing legend.
- P. C-212
1) Added:
a. Replacement of tree.
b. Replacement of tree to drawing legend.
2) Revised: Note #5.
- Q. C-402A
1) Revised: Notes on details 22, 23, and 24.
- R. C-404
1) Revised:
a. Detail C.
b. Detail D.
- S. C-408
1) Added: Detail 32 to remove existing steam trap protective barrier.
- T. C-507
1) Revised:
a. Limit of disturbance and construction fence in front of Norman Hall.
b. Labels and callouts in front of Norman Hall.
c. Alternate #2 limits.
- U. C-600
1) Revised: Phasing notes and dates associated with each phase.
- V. H-005
1) Revised: Identified correct building sign. Identified stop sign to remain.

- W. H-007
1) Added: Identification of truncated dome ADA pavers.
- X. L-005
1) Revised: Deleted redundant crosswalk.
- Y. MGA-101
1) Revised: Drawing viewport to show more manholes in site map.
- Z. MGA-201
1) Revised: Drawing viewport to show more manholes in site map.
- AA. MGA-401
1) Revised: Extents of schematic to show SM-3D3-77.
- BB. MGA-501
1) Revised: Extents of schematic to show SM-3D3-77.
- CC. M-301
1) Revised:
a. Sections to show removal of protective barrier around steam trap station in pedestrian tunnel and remove alternate work.
b. Drawing notes to remove alternate work.
- DD. EL-105
1) Revised: Drawing Note 1 grounding conductor size increased.
- EE. EL-106
1) Revised: Drawing Note 1 grounding conductor size increased.

SPECIFICATION REVISIONS:

- A. Section 00 00 10 – Table of Contents
1) Revised: “Appendix – Existing Conditions Information”, to be “Appendix A – Existing Conditions Information.”
2) Added: Appendix B – State of Florida Department of Transportation SW 13th Street Permit.

- B. Section 00 90 30 – Asbestos
 - 1) Added: Subsection 1.1.B.
- C. Section 01 01 10 – Project Phasing
 - 1) Added: Subsection 1.3.C.1.t. – 1.3.C.1.y.
 - 2) Revised:
 - a. Subsection 1.4.G.2.f. to correctly reference SM-3D3-78.
 - b. Subsection 1.4.G.4.b.4) to connect the 6” 70S on the western side of the pedestrian tunnel.
- D. Section 01 31 00 – Construction Schedules
 - 1) Revised: Subsection 2.1.G. to extend the project end date to August 15, 2024.
- E. Section 33 63 13 – Direct Buried Underground Steam and Condensate Piping Systems
 - 1) Revised: Subsection 2.1.F. to allow both galvanized or fusion boned epoxy coated outer conduit.
- F. Appendix A – Existing Condition Information
 - 1) Revised: Section title.
- G. Appendix B – State of Florida Department of Transportation SW 13th Street Permit
 - 1) Added: Section.

OTHER:

A. None

- Specifications attached: As noted above.
- Drawings/sketches attached: As noted above.
- Other: None

Elizabeth Nolder, P.E.